Equipment schedule

scale : none

MULTI V Indoor unit

MARK	MODEL	TYPE	QTY	COOLING CAPACITY			HEATING CAPACITY			FAN		POWER INPUT (kW)		PIPING CONNECTIONS (mm)			POWER	WEIGHT (kg)		DIMENSION (WxDxH) (mm)		REMARK
				Btu/h	kW	kcal/h	Btu/h	kW	kcal/h	TYPE	AIR FLOW(CMM)	Cooling	Heating	LIQUID	GAS	DRAIN (ID)	□/V/Hz	BODY	PANEL	BODY	PANEL	
IAC-2	ARNU24GL3G4	Low Static Duct	5	24000	7,10	6100	27300	8,00	6900	SiroccoFan	20,0/16,0/12,0	0,12	0,12	9,52	15,88	25	1/220-240/50,1/220/60	27	-	1100x700x190	-	-

Facility ID : OAC-1-1
Model : ARUM120LTE5
ODU Capacity(kW) : 33,6/ 37,8
Additional refrigerant(kg) : 5,01
Install Location : 2F

MULTI V Outdoor unit

MARK	MODEL	TYPE	QTY	COOLING CAPACITY		
				Btu/h	kW	kcal/h
OAC-1	ARUM120LTE5	MULTI V 5	1	152900	33,60	38528



Y Branch

INDEX	Y Branch
Y1	ARBLN01621
Y2	ARBLN03321
Y3	ARBLN07121
Y4	ARBLN14521
Y5	ARBLN23220
Y6	ARBLB01621
Y7	ARBLB03321
Y8	ARBLB07121
Y9	ARBLB14521
Y10	ARBLB23220

PRACOWNIA PROJEKTOWO KONSERWATORSKA "PROKON S.C."
"PROKON S. C"
Pracownia:
OPOLE 45-083, ul. Barlickiego 13, tel. 77 454 76 11 fax 77 423 11 77, 601 921 008, e-mail: poczta@prokon.hub.pl

INWESTYCJA
Uniwersytet Opolski
Pl. Kopernika 11A, 45-040 Opole

INWESTYCJA
Opracowanie dokumentacji projektowej, kosztorysów inwestorskich, STWiOR i inwentaryzacji dla budynku przy ul. Oleskiej 48 w Opolu

OBIEKT
Uniwersytet Opolski przy ul.Oleskiej 48 , dz. nr 12/7

TREŚĆ RYSUNKU
REMONT POMIESZCZEŃ BIBLIOTEKI - SCHEMTA KLIMATYZACJI

INSTALACJE SANITARNE	PROJEKTOWAŁ: Inż. Stanisław Boduszek	NR UPRAWNIEŃ 586/93	PODPIS	DATA 17.08.2017	STADIUM PROJEKT WYKONAWCZY
	SPRAWDZIŁ:	NR UPRAWNIEŃ	PODPIS	DATA 17.08.2017	
KONSTRUKCJA	PROJEKT:	NR UPRAWNIEŃ	PODPIS	DATA 17.08.2017	BRANŻA INSTALACJA SANITARNA
	SPRAWDZIŁ:	NR UPRAWNIEŃ	PODPIS	DATA 17.08.2017	SKALA - / NR RYSUNKU 2s

WYCIĄGI NA PRAWA AUTORSKIE DOSTARCZONE